

From: [Prestbo, Kim](#)
To: [Cooke, Maryt](#); [Bilbrey, Sheryl](#); [Bottcher, Helen](#); [Fleming, Sheila](#); [Faulk, Dennis](#); [Psyk, Christine](#); [Szerlog, Michael](#)
Cc: [Repasky, Ted](#); [Bachman, Brenda](#); [Allen, Elizabeth](#); [Dunbar, Bill](#)
Subject: RE: Update on Fairchild AFB PFOS/PFOA Sampling and Response
Date: Friday, June 09, 2017 12:15:00 PM

Good Morning,

On Thursday June 8, the City of Airway Heights received confirmation results that 20 out of 21 test results were below the Health Advisory or 'non-detect'. One location that was just above the HA was isolated from the rest of the distribution system. Therefore, the city has removed the advisory that was put in place on May 16 and water is now available to the public and businesses. The two contaminated municipal wells will remain shut down while the city and Air Force evaluate long-term alternative water supplies or filtration technologies. As part of Phase 3, this week the Air Force completed sampling of the on-base perimeter groundwater monitoring wells.

From: Prestbo, Kim
Sent: Tuesday, June 06, 2017 11:18 AM
To: Cooke, Maryt <Cooke.Maryt@epa.gov>; Bilbrey, Sheryl <bilbrey.sheryl@epa.gov>; Bottcher, Helen <Bottcher.Helen@epa.gov>; Fleming, Sheila <fleming.sheila@epa.gov>; Faulk, Dennis <Faulk.Dennis@epa.gov>; Psyk, Christine <Psyk.Christine@epa.gov>; Szerlog, Michael <Szerlog.Michael@epa.gov>
Cc: Repasky, Ted <repasky.ted@epa.gov>; Bachman, Brenda <bachman.brenda@epa.gov>; Allen, Elizabeth <allen.elizabeth@epa.gov>; Dunbar, Bill <dunbar.bill@epa.gov>
Subject: Update on Fairchild AFB PFOS/PFOA Sampling and Response

Good Morning,

I was able to catch up with my POC (Jarrod Case) at Fairchild yesterday afternoon. Current status is provided in the attached pdf with figures, but also summarized below. Please forward to others that may be interested in this update.

June 6, 2017

Fairchild Air Force Base PFOS/PFOA Update

Preliminary results from Phase 2 sampling (located on Figure 1) indicate that 3 residential wells have total PFOS/PFOA concentrations above the health advisory (HA - 70 ppt) - in addition to the Airway Heights municipal wells PS1/4 and #9 with concentrations of 1400 ppt and 1520 ppt, respectively. The Phase 2 residential exceedances were located to the south of the Phase 1 Sampling Area along Craig Road (see Figure 1). Fairchild is not providing details regarding specific location or concentration within these residential wells. Two Fairchild groundwater monitoring wells (MW-117 and MW-127) in the northeast portion of the Phase 2 area (closest to the municipal wells) were non detect and below the HA.

A technical team at AFCEC is planning the Phase 3 sampling program which will include the following:

- 1) Immediate sampling of on base groundwater monitoring wells along the northern and

eastern perimeter of the Base.

- 2) Identification and sampling of all residential wells and municipal Group B wells within the area outlined in blue on Figure 2. Once identified, property owners will be contacted for access to sample.

EPA has not been invited to join the Phase 3 scoping team but general information is being provided upon request. It is not clear whether Fairchild plans to sample upgradient groundwater monitoring wells associated with Craig Road Landfill, which is a non-contiguous Fairchild AFB Operable Unit being remediated for TCE. We are providing a list of recommended wells on-site and off-site downgradient of Craig Road Landfill to better understand potential sources of PFOS/PFOA. The City of Airway Heights continues to flush their distribution system associated with the impacted municipal wells, but as of Friday June 2 after a 3rd round of testing there were still samples exceeding the HA. A total of 20 samples were collected from various locations throughout the city and 4 samples had concentrations ranging from 85 – 141 ppt. The remaining samples showed 'non-detect'. One sample located in the industrial area has been isolated with a concentration of 1245 ppt. The community remains on bottled water.

Kim Prestbo, Remedial Project Manager
Office of Environmental Cleanup
USEPA Region 10, Seattle
Ph: (206) 553-0239
prestbo.kim@epa.gov